



October 19, 2009

PRINSCO, INC.
CHATSWORTH FACILITY
JOE LARKINS
111 E PINE ST.
CHATSWORTH IL 60921

Re: Description: PIPES AND FITTINGS, POLYETHYLENE
Manufacturer: PRINSCO, INC.
Product Name: PRINSCO GOLDLINE SINGLE WALL PIPE
Model Number(s): PIPE 3, 4, 5, 6, 8, 10, 12, 15
FITTINGS 90 DEGREE ELL: 3, 4; STRAIGHT TEE: 4, 5, 6; COMBO TEE: 3 x 4; BLIND
TEE: 4, 5, 6, 8, 10, 12, 15; REDUCING TEE: 5, 6, 8, 10, 12, 15; WYE: 3, 4, 5, 6, 8; STEP
DOWN REDUCER: 4x3, 6x5x4, 5x4, 6x4, 6x5, 8x4, 8x6, 10x4, 10x8, 10x8x6, 12x10,
12x10x8, 15x12, 15x12x10; PLASTA PLUG: 3, 4, 5, 6; INTERNAL END PLUG: 3, 4, 5, 6, 8;
EXTERNAL END CAP PLUG: 8, 10, 12, 15; INTERNAL SNAP COUPLER: 3, 4, 5, 6, 8;
SOIL-TIGHT COUPLER: EXTERNAL SNAP COUPLER: 4, 6, 8, 10, 12, 15; SLEEVE
COUPLER KIT: 12, 15; SILT-TIGHT COUPLER: 12, 15.
Product File No: 20090347

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (2) and (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain or vent use(s):
 - a. Sanitary sewer gravity flow
 - b. Storm sewer gravity flow
 - c. Stormwater infiltration piping gravity flow perforated
- This product is installed for POWTS effluent piping, the product must have 2 rows, and only 2 rows, of perforations parallel to the axis of the pipe and 120 degrees plus/minus 5 degrees apart. The perforations shall be at the nominal 4 and 8 o'clock positions what the pipe is installed.
- This product must be labeled with the following information:
 - a. Manufacturer's name or trademark
 - b. Date of manufacture
 - c. National standard to which the pipe meets
 - d. Nominal size
 - e. Plant designation
 - f. Production line

This approval supersedes the approval issued on July 2, 2004 under product file number 20040244.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040244.

PRINSCO, INC
Page 2
October 19, 2009
20090347

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov